

NEW OKHLA INDUSTRIAL DEVELOPMENT AUTHORITY

Office Of The Senior Manager, Jal Division – III,
Sector-39, Noida.

No. Noida/S.M.(Jal)-III/2019/ 96

Dated 08/05/19

TO WHOM IT MAY CONCERN:

After the Inspection it is certified that LPS Global School, D-196/2, Sector-51, Noida. has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/UP Govt.

The above valid for a period of 30 April 2020.

Place : Noida
Date : 08/05/2019

M. Singh
08/05/19
**Senior Manager
Jal Division-III**



ITL LABS PVT. LTD.

Govt. Approved Test House

B-283-84, Mangolpuri, Industrial Area, Phase-I, Delhi - 110 083

PH. : 27915654, 27915608, 65368717, Fax : 27923339

Toll Free No. 1800-532-0999

TEST REPORT

ULR: TC513319300001666F

Page 1 of 1

Report No.	: W201903120016	Date of Reporting	: 19/03/2019
Issued to	: CAMPTY FALL BEVERAGES PLOT NO. 4, HOSIYARPUR, SECTOR-51, NOIDA-201301	Date of Receipt	: 12/03/2019
		Test Started on	: 12/03/2019
		Issue of test report	: 19/03/2019
		CM/L NO.	: None
Nature of Sample	: PACKAGED DRINKING WATER (Monthly)	Batch No. & DOM.	: 1003 & 10/03/2019
Brand Name	: NONE	Expiry Date	: None
Sample Packing	: PET JAR	Sample Qty.	: 1 x 20 LTR

TEST REPORT AS PER IS:14543:2016 (Amendment No. 3)

Clause 5.2: Microbiological Requirements

S. No.	Tests/Cl. Ref	Specified Requirements	Results
i	Faecal streptococci, IS:5887 (Part-II):1976	Absent / 250 ml	Absent
ii	Staphylococcus aureus, IS:5887 (Part-II):1976	Absent / 250 ml	Absent
iii	Salmonella, IS:15187 -2016	Absent / 250 ml	Absent
iv	Shigella, IS:5887 (Part-VII):1999	Absent / 250 ml	Absent
v	Vibrio cholera, IS:5887 (Part-V):1976	Absent / 250 ml	Absent
vi	Vibrio parahaemolyticus, IS:5887 (Part-V):1976	Absent / 250 ml	Absent

Reviewed by

Authorized Signatory
(Nishtha Sharma)

Clause 5.3: General Requirements

S. No.	Tests/Cl. Ref	Specified Requirements	Results
i.	Description, Visual	Water shall be clear without any sediments, suspended particles & extraneous matter	Water is clear without any sediments, suspended particles & extraneous matter

Clause 5.4: Table 2: General Parameters Concerning Substances Undesirable in Excessive Amounts

S. No.	Tests/Cl. Ref	Specified Requirements	Detection Limit	Results
I	Zinc (as Zn), IS:3025(Part-2)2004, mg/l, Max	5.0	0.025	BDL
ii	Phenolic compounds (as C ₆ H ₅ OH), IS:3025 (Part-43):1992, mg/l, Max	Absent	0.001	Absent
iii	Mineral oil, Clause-6 of IS:3025 (Part-39):1991, mg/l, Max	Absent	0.5	Absent
iv	Anionic surface active agents (as MBAS), Annex-K of IS:13428:2005,mg/l, Max	0.2	0.1	BDL
v	Antimony (as Sb), Annex-G of IS:13428:2005, mg/l, Max	0.005	0.002	BDL
vi	Borates (as B), IS:3025(Part-2)2004,mg/l, Max	5.0	0.1	BDL

BDL: Below Detection Limit. .

****End of Report****

REMARKS: Party asked for the above tests only. the no. of parameters tested are 13 only. the test report is issued subject to the terms & conditions mentioned overleaf

Reviewed by

Authorized Signatory
(Basudev Singh)